

AUGUSTA COUNTY SERVICE AUTHORITY

18 Government Center Lane, P.O. Box 859

Verona, VA 24482

Phone: 540-245-5228

Fax: 540-245-5087

Backflow Prevention Assembly

Test Report

Mailing Address: _____

Size: _____
 Device: _____

Serial #: _____

Test Performed By: _____

Test Due: _____

Company Name: _____

Last Test: _____

Address: _____

Service Address: _____

Location: _____

	Reduced Pressure Principle Assembly			RP <input type="checkbox"/>	DCDA <input type="checkbox"/>
				DC <input type="checkbox"/>	RPDA <input type="checkbox"/>
	Double Check Valve Assembly			PVB <input type="checkbox"/>	Air Gap <input type="checkbox"/>
				SVB <input type="checkbox"/>	AVB <input type="checkbox"/>
	Check Valve #1	Check Valve #2	Relief Valve	PVB/SVB	
Initial Test	Leaked <input type="checkbox"/> Closed Tight <input type="checkbox"/> Min. 5.0 PSID Held at _____ PSID	Leaked <input type="checkbox"/> Closed Tight <input type="checkbox"/> Min. 1.0 PSID Held at _____ PSID	Did not Open <input type="checkbox"/> Must Open Min. of 2.0 PSID Opened at _____ PSID	AIR INLET Did not Open <input type="checkbox"/> Opened at _____ PSID	
Repairs	Cleaned <input type="checkbox"/> Replaced <input type="checkbox"/>	Cleaned <input type="checkbox"/> Replaced <input type="checkbox"/>	Cleaned <input type="checkbox"/> Replaced <input type="checkbox"/>	CHECK VALVE Leaked <input type="checkbox"/> Held at _____ PSID	
Details				Cleaned <input type="checkbox"/> Replaced <input type="checkbox"/> AIR INLET Opened at _____ PSID	
Final Test	Closed Tight <input type="checkbox"/> Held at _____ PSID	Closed Tight <input type="checkbox"/> Held at _____ PSID	Opened at _____ PSID	CHECK VALVE Held at _____ PSID	

Comments

Line Pressure _____
 Meter Reading _____
 Held Backpressure _____
 #2 Shutoff _____
 Relief Valve Exercised _____

The above report is certified to be true.

	Date/Time	Tester	Signature	Tester #	Test Kit	Passed	Failed
Initial Test						<input type="checkbox"/>	<input type="checkbox"/>
Repairs						<input type="checkbox"/>	<input type="checkbox"/>
Final Test						<input type="checkbox"/>	<input type="checkbox"/>