



City of Portsmouth
Department of Public Utilities
Backflow Prevention Device Test Report

Name of Premises _____

Service Address _____

Use & Location of Device _____

Device _____
 Manufacturer _____ Model _____ Type _____ Size _____ Serial # _____

Line Pressure at Time of Test _____ psi		Existing / Replacement / New Device (circle one)		
Reduced Pressure Device	Requirement	Initial Test	Repairs	Retest
Check Valve #1 Pressure diff. across Ck. Valve #1	Closed Tight ? min of 5.0 psid	yes / no (circle one) _____ psid (A)		yes / no (circle one) _____ psid (A)
Check Valve #2	Closed Tight ?	yes / no (circle one)		yes / no (circle one)
Differential Pressure Relief Port	Must open at min. of 2.0 psid	Opened at _____ psid (B)		Opened at _____ psid (B)
Static pressure across Ck. Valve #1	A - B ≥ 3.0 psid	_____ psid		_____ psid
Double Check Valve Device	Requirement	Initial Test	Repairs	Retest
Check Valve #1	Closed tight at a minimum of 1.0 psid?	yes / no (circle one) _____ psid		yes / no (circle one) _____ psid
Check Valve #2	Closed tight at a minimum of 1.0 psid?	yes / no (circle one) _____ psid		yes / no (circle one) _____ psid
Pressure / Anti Spill VB	Requirement	Initial Test	Repairs	Retest
Air Inlet	Opened at min. of 1.0 psid?	yes / no (circle one) _____ psid		yes / no (circle one) _____ psid
Check Valve	Closed at min. of 1.0 psid?	yes / no (circle one) _____ psid		yes / no (circle one) _____ psid

Remarks _____

Certification: I have made the above test and hereby certify that this backflow prevention device performed satisfactorily and meets all federal, state and local codes and regulations as required.

Tester Name _____ (Print) _____ (Signature) Date _____

Test Kit Serial # _____ Calibration Date _____

License # _____ Expiration date _____ City of Certification _____

Testing Company _____ Phone # _____

Company Address _____

Return a copy or fax to: City of Portsmouth
 Department of Public Utilities
 Cross Connection Control
 430 Meander Road
 Portsmouth, VA 23704-2944
 Phone: 757-393-8561 ext 124 Fax: 757-393-8412